

Spencer Solar Farm 6-7 - Database Notes

Table 1 Database Notes

Data Collection	Data Logger: Data Collection Interval: Collection Method: Timestamp Reference:	Locus Daily Locus Energy Email 5 min
Site Information	Azimuth: Tilt: Nameplate Capacity:	180° 20° 5963.065 kW
DG/CHP Solar Panel Output	Engineering Units: Measurement Type:	kWh Accumulator
DG/CHP Solar Panel Output Demand	Engineering Units: Measurement Type:	kW Calculated

Table 2 Event Timeline

Date	Event
October 10, 2019	Monitored data collection began
October 23, 2019	Monitored data posted on the NYSERDA DG Website

Table 3. Range Checks

Data Point	Hourly Data Method	Units	Database Lower Range	Database Upper Range	Notes
DG/CHP Generator Output	Sum	kWh/int	0	500	
DG/CHP Generator Output Demand	Max	kW	0	6000	
Ambient Temperature	Avg	°F	-20	130	WUG Airport Code – ITH

Notes: Table contains values from *spencer_solar67.csv*