

DELAWARE RIVER SOLAR 93 VILLA ROMA - 50835 – DATABASE NOTES

Table 1 Database Notes

Data Collection	Data Logger: Data Collection Interval: Collection Method: Timestamp Reference:	Generate Capital Daily FTP Upload to Frontier servers 15 min
Site Information	Azimuth: Tilt: Nameplate Capacity:	194° 20° 2317.68 kW
DG/CHP Solar Panel Output	Engineering Units: Measurement Type:	kWh Interval
DG/CHP Solar Panel Output Demand	Engineering Units: Measurement Type:	kW Calculated

Table 2 Event Timeline

Date	Event
January 30, 2020	Data collection begins.
February 12, 2020	Added to NYSERDA website.

DELAWARE RIVER SOLAR 93 VILLA ROMA - 50835 – DATABASE NOTES

Range Checks

Table 3 Range Checks

Data Point	Units	Database Lower Range	Database Upper Range	Notes
DG/CHP Generator Output	kWh/int	0	587.5	
DG/CHP Generator Output Demand	kW	0	2350	
Ambient Temperature	°F	-20	130	NOAA Airport Code - KSWF