

BORREGO SOLAR SYSTEMS, INC – 93863 – DATABASE NOTES

Table 1 Database Notes

Data Collection	Data Logger: Data Collection Interval: Collection Method: Timestamp Reference:	AlsoEnergy Daily Direct Upload 15 min
Site Information	Azimuth: Tilt: Nameplate Capacity:	180° 25° 5580.90 kW
DG/CHP Solar Panel Output	Engineering Units: Measurement Type:	kWh Interval
DG/CHP Solar Panel Output Demand	Engineering Units: Measurement Type:	kW Calculated

Table 2 Event Timeline

Date	Event
February 1, 2020	Data collection begins.
March 11, 2020	Added to NYSERDA website.

BORREGO SOLAR SYSTEMS, INC – 93863 – DATABASE NOTES

Range Checks

Table 3 Range Checks

Data Point	Units	Database Lower Range	Database Upper Range	Notes
DG/CHP Generator Output	kWh/int	0	1400	
DG/CHP Generator Output Demand	kW	0	5600	
Ambient Temperature	°F	-20	130	NOAA Airport Code - KPOU