

WALDEN NY 1, LLC - 757 ROUTE 52 - PV SYSTEMS – 153079 – DATABASE NOTES

Table 1 Database Notes

| | | |
|---|---|---|
| Data Collection | Data Logger: Data Collection Interval: Collection Method: Timestamp Reference: | Inaccess Daily Inaccess Email 15 min |
| Site Information | Azimuth: Tilt: Nameplate Capacity: | 180° 25° 2684.640 kW |
| DG/CHP Solar Panel Output | Engineering Units: Measurement Type: | kWh Interval |
| DG/CHP Solar Panel Output Demand | Engineering Units: Measurement Type: | kW Calculated |

Table 2 Event Timeline

| Date | Event |
|-----------------|---------------------------|
| July 20, 2020 | Data collection begins. |
| August 10, 2020 | Added to NYSERDA website. |

WALDEN NY 1, LLC - 757 ROUTE 52 - PV SYSTEMS – 153079 – DATABASE NOTES

Range Checks

Table 3 Range Checks

| Data Point | Units | Database Lower Range | Database Upper Range | Notes |
|---------------------------------------|--------------|-----------------------------|-----------------------------|--------------------------|
| DG/CHP Generator Output | kWh/int | 0 | 675 | |
| DG/CHP Generator Output Demand | kW | 0 | 2700 | |
| Ambient Temperature | °F | -20 | 130 | NOAA Airport Code - KSWF |