

OYA BLANCHARD ROAD

Table 1 Database Notes

Data Collection	Data Logger: Data Collection Interval: Collection Method: Timestamp Reference:	AlsoEnergy Daily Direct Upload 15 min
Site Information	Azimuth: Tilt: Nameplate Capacity:	180° +/- 60° (SAT) 7602.400 kW
DG/CHP Solar Panel Output	Engineering Units: Measurement Type:	kWh Interval
DG/CHP Solar Panel Output Demand	Engineering Units: Measurement Type:	kW Calculated

Table 2 Event Timeline

Date	Event
July 10, 2020	Data collection begins.
December 30, 2020	Added to NYSERDA website.

OYA BLANCHARD ROAD

Range Checks

Table 3 Range Checks

Data Point	Units	Database Lower Range	Database Upper Range	Notes
DG/CHP Generator Output	kWh/int	0	1925	
DG/CHP Generator Output Demand	kW	0	7700	
Ambient Temperature	°F	-20	130	NOAA Airport Code - KART