

Table 1 Database Notes

Data Collection	Meter: Data Logger: Data Collection Interval: Collection Method:	AlsoEnergy sFTP Daily 15 min AlsoEnergy sFTP
Project Information	Azimuth: Tilt: Nameplate Capacity:	98° 60° 5,895.120 kW-DC
DER Electricity Generated (WG)	Engineering Units: Measurement Type:	kWh Interval

Table 2 Event Timeline

Date	Event
February 10, 2025	Data collection begins.
March 17, 2025	Added to NYSERDA website.

Range Checks

Table 3 Range Checks

Data Point	Units	Database Lower Range	Database Upper Range	Notes
DER Electricity Generated	kWh/hour	0	5900	
Ambient Temperature	°F	-20	130	NOAA Airport Code - KSYR