

South Hill Business Campus– Database Notes

Table 1 Database Notes

Data Collection	<u>Data Logger:</u> <u>Data Collection Interval:</u> <u>Collection Method:</u>	ASI Energy 5 minute Email
Site Information	<u>Cogeneration Units:</u> <u>Nameplate Capacity:</u> <u>Heat Recovery Medium:</u> <u>Heat Recovery Uses:</u> <u>Excess Heat:</u>	2 Engines 250 kW each Hot Water Heating/Cooling Dump radiator
DG/CHP Generator Electrical Output	<u>Engineering Units:</u> <u>Energy Measurement (net/gross):</u> <u>Measurement Type:</u>	kWh from Accumulator
DG/CHP Generator Electrical Output Demand	<u>Engineering Units:</u> <u>Measurement Type:</u>	kW Rate
DG/CHP Generator Fuel Input	<u>Engineering Units:</u> <u>Measurement type:</u>	Cf Pulse counter from utility meter
DG/CHP Useful Heat Recovery	<u>Engineering Units:</u> <u>Heat Measurement Type:</u>	MBtu/h From btu meter
DG/CHP Status/Runtime	<u>Engineering Units:</u> <u>Measurement Type:</u>	

South Hill Business Campus– Database Notes

Table 2 Event Timeline

Date	Event
2/19/2018	Data has been posted to NYSERDA DG website

Range Checks

Table 3. Range Checks

Data Point	Units	Hourly Data Calculation Method	Database Lower Range	Database Upper Range	Notes
DG/CHP Generator Output (WG_d)	kWh/int	Sum	0	150	
DG/CHP Generator Output Demand (WG_KW_d)	kW	Max	0	600	
DG/CHP Generator Gas Use (FG_d)	cf/int	Sum	0	1750	
Useful Heat Recovery (QHR_d)	MBtu/int	-	-500	6000	
Unused Heat Recovery (QD_d)	MBtu/int	-	0	6000	
Ambient Temperature (TAO)	°F	Avg	-20	130	

Notes:

1. This table contains values from *shbc.csv*