

Upstate Cerebral Palsy Barneveld - Database Notes

Table 1 Database Notes

Data Collection	Data Logger: Data Collection Interval: Collection Method: Timestamp Reference:	GreenPM Daily FTP 15 min
Site Information	Azimuth: Tilt: Nameplate Capacity:	180° 22° 1400.8 kW
DG/CHP Solar Panel Output	Engineering Units: Measurement Type:	kWh Interval
DG/CHP Solar Panel Output Demand	Engineering Units: Measurement Type:	kW Calculated

Table 2 Event Timeline

Date	Event
May 17, 2019	Monitored data collection began
May 21, 2019	Monitored data posted on the NYSERDA DG Website

Data Point	Hourly Data Method	Units	Database Lower Range	Database Upper Range	Notes
DG/CHP Generator Output	Sum	kWh/int	0	350	
DG/CHP Generator Output Demand	Max	kW	0	1400	
Ambient Temperature	Avg	°F	-20	130	WUG Airport Code – SYR

Notes: Table contains values from *upc_barneveld.csv*